

KIRLOSKAR DIESEL GENERATING SETS



KG35W / KG35WS

Diesel Generating Set Output Ratings					
Model	at 0.8 of (lag) at 0.8 of (lag) Voltage Voltage				Optional Voltage (L-L)
KG35W (OPEN)	35 kVA	38.5 kVA	3 Phase /	220V	380V to
KG35WS (SAE)	28 kW	30.8 kW	60 Hz	220 V	480V*

, ,

SAE – Sound Attenuated Enclosure * kVA rating may change please consult KOEL

Ratings are according to ISO 8528; refer to ratings definition on page 2.



Note: Above picture shown for illustration purpose only, actual product may be different.

Features

- Extremely reliable.
- Lower operating cost.
- Easy maintenance higher uptime.
- Sound attenuating enclosure (canopy) is fully integrated and designed for all weather conditions (weather proof).
- Best in class Sound attenuation 70 dB(A) at 7 meters as per ISO 8528
- State of the art generating set control system with high degree of accuracy and reliability.
- Ideally suitable for critical industries like Construction, Manufacturing, Textile, Services etc.
- Superior design standards that minimize power deration even at high ambient temperatures.
- Efficient and prompt after sales service available.



Ratings Definition:



Emergency Standby Power (ESP):

Enriching Lives

Emergency standby power is defined as the maximum power available during a variable electrical power sequence, under the stated operating conditions, for which a generating set is capable of delivering in the event of utility power outage. The permissible average power output over 24hours of operation shall not exceed 70% of the ESP. No overload is permitted above ESP rating.

Prime Rated Power (PRP):

These ratings are applicable for supplying continuous electrical power (at variable load) in lieu of commercial purchased power. There is no limitation to the annual hours of operation and this model can supply 10% overload power for 1 hour in 12 hours.

Continuous Rated Power:

These ratings are applicable for supplying power continuously to a constant load upto the full output rating for unlimited hours. No sustained overload capability is available for this rating.

GENERATING SET SPECIFICATIONS		
Model - Open Type KG35W		35W
Model - SAE Type	KG35WS	
Line Voltage (Volts)	220V 380V	
Phase Voltage (Volts)	Phase Voltage (Volts) 127V 220V	
Frequency (Hz)	6	0
Power Factor	0.8	
Phase	Three phase	
First Tank Canasity (Litara)	Open – 65	
Fuel Tank Capacity (Liters)	SAE – 75	
Fuel consumption at 100% load (lit/hr) +5% tolerance	9.6	
Fuel consumption at 75% load (lit/hr) +5% tolerance	7.2	
Sound level at 7 m for Silent Generating set dB	70	
Overall dimensions (cms)	Open – 150 x 109 x 134	
(SAE – 219 x 100 x 153	
Moight (kgg)	Open Type – 790	
Weight (kgs)	SAE Type – 1100	

CONTROL SYSTEM		
DSE TO BE DOSE		
Controller Make	Deepsea	
Controller Model	DSE 6120 MKII	
Digital display instrumentation	Generator Voltage Generator Amps Generator Frequency Generator kW, kVA, kVAr Generator kWh Generator power factor Mains Voltage Battery Voltage Engine hours Run Oil Pressure Gauge Engine Temperature Gauge Fuel Level	
Shutdowns/Safeties	Fail to Stop Low Oil pressure High Engine Temperature Under/Over-speed Under/Over voltage Emergency Stop Failed to reach loading voltage Failed to reach loading frequency Charge Fail Over Current Low DC Voltage warning Low coolant level	
Automatic Starting & AMF facility	Available	



Engine Technical Data



Enriching Lives

Physical Data		
Engine Make	Kirloskar	
Engine Model	3R1040	
Number of cylinders	3	
Configuration	Inline	
Type Four stroke		
Bore x Stroke (mm) 105 x 120		
Displacement (Ltr)	3.12	
Cooling	Water cooled	
Aspiration	Natural	
Compression Ratio	18 : 1	
Starting Arrangement	12V Electric	

Fuel System		
Type of fuel filter	Two stage spin on type	
Governor Type	Mechanical	
Class of Governing	ISO 8528-5, Class G2	
Fuel pump type	Inline	
Fuel pump make	Mico Bosch	
Recommended Fuel	Class A2, High speed diesel	
Fuel consumption at 100% load (lit/hr) +5% tolerance	9.6	
Fuel consumption at 75% load (lit/hr) +5% tolerance 7.2		
Fuel consumption readings are based on diesel fuel with a specific gravity of 0.85 and confirming to BS 2869, Class A2)		

Air System		
Air Filter Type Dry type replaceat element		
Air Volume required for Ventilation (m³/hr)	4011	
Combustion air flow (m³/hr)	140	
Total Air Flow required for ventilation (m³/hr)	4263	
Total Fresh air required (m³/hr)	4472	

Lubrication System		
Type of lube oil filter	Full flow spin on type	
Oil to be used	SAE 15W-40 API : CI4	
Oil pump type	Through G-rotor gear pump	
Lub oil sump capacity (lit)	9	
Lube oil consumption	0.3% of fuel consumption	

Cooling System		
Cooling system capacity (lit)	12	
Water pump type	Centrifugal	
Radiator fan load (hp)	2	

Electrical System		
Starting Arrangement	12V Electric	
Starter	12V Electric	
Starter Battery Rating	100Ah	
Battery charging alternator	Engine mounted 12V battery charger	
Battery charger amps	35	





Alternator Technical Data

Enriching Lives

Physical Data		
Line Voltage (Volts)	220V 380V	
Manufacturer	Manufacturer Stamford	
Model	PI 144 G1 PI 144 G1	
Number of bearings	1	
Insulation class	Н	
Winding pitch 2/3		/3
Wires	12	
Ingress Protection Rating	IP 23	
AVR Model AS 480		480

Operating Data		
Line Voltage (Volts)	220V 380V	
Over speed (RPM)	22	50
Excitation	Self excited	
Efficiency (%)	86.6 86.7	
THD at full linear balanced load AC waveform	<u>< </u>	5%
Voltage Regulation (%)	± ′	1.0
Reactance per unit (Xd)	1.97 2.06	
Reactance per unit (X'd)	0.18 0.19	
Reactance per unit (X"d)	unit (X"d) 0.13 0.14	

Sound Attenuating Enclosure (Canopy)

Sound Level	70 dB at 7 meter as per ISO 8528	
Construction	 Fully Integrated, metal construction for ALL WEATHER USE (weather proof). Black zinc die cast, Aluminium hinges or Stainless steel hinges tested to withstand corrosive environment conditions. Fuel filling spout with lock. Emergency stop button on canopy exterior. Provision of glass window for viewing control panel Provision for lifting canopy 	
Maintenance	Easy access through lockable doors for operation/maintenance and repair works (including access for radiator service)	
Protection Standard	IP 21 Standard	

General Data

Documents	A full set of Illustrated
	spare parts catalogue
	Operation &
	Maintenance manual
	Circuit Diagrams
Quality Standards	ISO 8528, ISO 3046, IS
	100002, BS5514, DIN
	6271, ISO 9001, ISO 14001



KIRLOSKAR OIL ENGINES LIMITED

Head Office: Laxmanrao Kirloskar Road, Khadki, Pune 411 003, India. Tel.: +91 20 2581 0341 / 534 Fax: +91 20 2581 3208 Website: www.koel.co.in

International business offices **KIRLOSKAR DMCC**

JBC-5, Cluster W, Jumeirah Lake Towers, P.O.Box 37745, Dubai. U.A.E Tel.: +971 4 443 8591 Fax: +971 4 441 4532

Email: enquiry@kirloskar.ae Website : www.kirloskar.ae

JOBURG INDUSTRIAL TRADING S.A.(Pty) LTD.

Unit B1, The Stables Business Park, Cnr of Third Avenue & Second Road, Limbro Park, Modderfontein, Johannesburg.

KIRLOSKAR KENYA LTD.

KOEL AMERICAS CORPORATION

Suite 4, Tamina Business Park, 32407 Tamina Road, Magnolia 77354, Texas USA Tel.: +1 832 675 1595 Email: Vinay.Kulkarni@koelamerica.com



